



Austin Fire Department

Fire Marshals Office
6310 Wilhelmina Delco Dr., Austin, TX 78752
(512) 974-0160

Mobile Vending Electrical Inspection Form

Mobile Vending Unit (MVU) Information

Date:	
-------	--

MVU Name:	
MVU Owner's Name:	
License Plate or VIN:	

Compliance Statement

The above identified MVU has been inspected to confirm that this unit meets or exceeds all national, state, and local laws and amendments. This inspection included, but was not limited to, the following:

No exposed high voltage wire/connections (AC/DC)	No broken/painted outlets/switches
No open junction boxes	Propane leak detection is operational (if hardwired)
All breakers are labeled	Proper wire size/type is used
No open slots inside breaker panel	Propane system is grounded appropriately
Breakers are not hot to the touch	Properly grounded AC/DC systems
GFCI outlets installed as required	Generator grounded/functioning properly
All fixtures are operational and undamaged	Wiring is in conduit

Select appropriate action item:

- I attest a visual inspection of the Mobile Food Unit has been completed by a Texas licensed electrician and all work within this unit meets or exceeds all national and local electrical codes.
- I attest this is a new build (within one year of inspection date) and all work was performed by a licensed electrician and meets or exceeds all national and local electrical codes. No inspection required.

Company Name:	
License Number:	
Company Phone Number:	
Company Email:	
Electrician's Name:	
Electrician's Signature:	