

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 02/01/2023 - 02/28/2023

Parameter	Units	Davis WTP			Ullrich WTP			Handcox WTP		
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6			
		Max	9.7	Max	9.8	Max	9.6			
		Min	9.5	Min	9.5	Min	9.6			
Total Alkalinity	mg/L as CaCO3	Avg	77	Avg	70	Avg	88			
		Max	82	Max	74	Max	94			
		Min	71	Min	66	Min	84			
Total Hardness	mg/L as CaCO3	Avg	113	Avg	105	Avg	116			
		Max	118	Max	109	Max	120			
		Min	108	Min	102	Min	112			
Total Solids	mg/L	Avg	237	Avg	264	Avg	230			
		Max	286	Max	302	Max	264			
		Min	208	Min	226	Min	200			
Total Chloramines	mg/L	Avg	2.75	Avg	2.69	Avg	2.71			
		Max	2.85	Max	2.85	Max	2.75			
		Min	2.65	Min	2.50	Min	2.60			
Total Organic Carbon	mg/L	Avg	2.89	Avg	2.64	Avg	2.86			
		Max	3.03	Max	2.75	Max	2.92			
		Min	2.76	Min	2.57	Min	2.80			
Conductivity	umhos/cm	Avg	375	Avg	370	Avg	402			
		Max	377	Max	370	Max	402			
		Min	372	Min	370	Min	402			
Total Trihalomethanes	ug/L	Avg	25.3	Avg	26.9	Avg	27.0			
		Max	26.0	Max	26.9	Max	27.0			
		Min	24.6	Min	26.9	Min	27.0			
Turbidity	NTU	Avg	.07	Avg	.04	Avg	.05			
		Max	.09	Max	.07	Max	.09			
		Min	.06	Min	.02	Min	.03			