

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 07/01/2022 - 07/31/2022

| Parameter | Units | Davis WTP | | | Ullrich WTP | | Handcox WTP | |
|-----------------------|---------------|-----------|------|-----|-------------|-----|-------------|--|
| pH | SU | Avg | 9.7 | Avg | 9.8 | Avg | 9.7 | |
| | | Max | 9.8 | Max | 9.9 | Max | 9.7 | |
| | | Min | 9.7 | Min | 9.7 | Min | 9.6 | |
| Total Alkalinity | mg/L as CaCO3 | Avg | 59 | Avg | 59 | Avg | 66 | |
| | | Max | 64 | Max | 65 | Max | 72 | |
| | | Min | 55 | Min | 57 | Min | 63 | |
| Total Hardness | mg/L as CaCO3 | Avg | 89 | Avg | 90 | Avg | 91 | |
| | | Max | 95 | Max | 92 | Max | 96 | |
| | | Min | 83 | Min | 88 | Min | 88 | |
| Total Solids | mg/L | Avg | 205 | Avg | 221 | Avg | 215 | |
| | | Max | 246 | Max | 252 | Max | 248 | |
| | | Min | 156 | Min | 196 | Min | 186 | |
| Total Chloramines | mg/L | Avg | 2.77 | Avg | 2.58 | Avg | 2.70 | |
| | | Max | 3.00 | Max | 2.70 | Max | 2.80 | |
| | | Min | 2.65 | Min | 2.45 | Min | 2.50 | |
| Total Organic Carbon | mg/L | Avg | 2.24 | Avg | 2.08 | Avg | 2.13 | |
| | | Max | 2.36 | Max | 2.15 | Max | 2.20 | |
| | | Min | 2.16 | Min | 1.98 | Min | 2.09 | |
| Conductivity | umhos/cm | Avg | 313 | Avg | 307 | Avg | 351 | |
| | | Max | 317 | Max | 307 | Max | 351 | |
| | | Min | 308 | Min | 307 | Min | 351 | |
| Total Trihalomethanes | ug/L | Avg | 36.4 | Avg | 24.3 | Avg | 20.3 | |
| | | Max | 38.9 | Max | 24.3 | Max | 20.3 | |
| | | Min | 33.8 | Min | 24.3 | Min | 20.3 | |
| Turbidity | NTU | Avg | .04 | Avg | .02 | Avg | .02 | |
| | | Max | .06 | Max | .07 | Max | .03 | |
| | | Min | .03 | Min | .01 | Min | .01 | |