

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 10/01/2023 - 10/31/2023

| Parameter | Units | Davis WTP | | | Ullrich WTP | | Handcox WTP | |
|-----------------------|---------------|-----------|------|-----|-------------|-----|-------------|--|
| pH | SU | Avg | 9.8 | Avg | 9.7 | Avg | 9.7 | |
| | | Max | 9.8 | Max | 9.9 | Max | 9.7 | |
| | | Min | 9.7 | Min | 9.5 | Min | 9.6 | |
| Total Alkalinity | mg/L as CaCO3 | Avg | 59 | Avg | 65 | Avg | 70 | |
| | | Max | 66 | Max | 70 | Max | 78 | |
| | | Min | 49 | Min | 56 | Min | 63 | |
| Total Hardness | mg/L as CaCO3 | Avg | 92 | Avg | 98 | Avg | 101 | |
| | | Max | 100 | Max | 105 | Max | 109 | |
| | | Min | 81 | Min | 91 | Min | 94 | |
| Total Solids | mg/L | Avg | 188 | Avg | 234 | Avg | 235 | |
| | | Max | 208 | Max | 256 | Max | 284 | |
| | | Min | 174 | Min | 204 | Min | 210 | |
| Total Chloramines | mg/L | Avg | 2.69 | Avg | 2.48 | Avg | 2.72 | |
| | | Max | 2.90 | Max | 2.75 | Max | 2.95 | |
| | | Min | 2.50 | Min | 2.25 | Min | 2.45 | |
| Total Organic Carbon | mg/L | Avg | 2.83 | Avg | 2.80 | Avg | 2.79 | |
| | | Max | 3.02 | Max | 2.95 | Max | 2.81 | |
| | | Min | 2.55 | Min | 2.68 | Min | 2.76 | |
| Conductivity | umhos/cm | Avg | 357 | Avg | 362 | Avg | 417 | |
| | | Max | 362 | Max | 368 | Max | 427 | |
| | | Min | 353 | Min | 355 | Min | 407 | |
| Total Trihalomethanes | ug/L | Avg | 44.8 | Avg | 23.7 | Avg | 28.1 | |
| | | Max | 47.1 | Max | 23.7 | Max | 28.1 | |
| | | Min | 42.4 | Min | 23.7 | Min | 28.1 | |
| Turbidity | NTU | Avg | .05 | Avg | .03 | Avg | .03 | |
| | | Max | .37 | Max | .05 | Max | .05 | |
| | | Min | .03 | Min | .02 | Min | .03 | |