

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 12/01/2022 - 12/31/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6	
		Max	9.7	Max	9.7	Max	9.7	
		Min	9.5	Min	9.4	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	72	Avg	69	Avg	80	
		Max	80	Max	74	Max	85	
		Min	66	Min	63	Min	76	
Total Hardness	mg/L as CaCO3	Avg	103	Avg	100	Avg	105	
		Max	110	Max	106	Max	110	
		Min	96	Min	93	Min	102	
Total Solids	mg/L	Avg	208	Avg	207	Avg	232	
		Max	218	Max	210	Max	252	
		Min	196	Min	204	Min	208	
Total Chloramines	mg/L	Avg	2.78	Avg	2.63	Avg	2.63	
		Max	2.95	Max	2.75	Max	2.85	
		Min	2.65	Min	2.55	Min	2.35	
Total Organic Carbon	mg/L	Avg	2.69	Avg	2.54	Avg	2.63	
		Max	2.93	Max	2.65	Max	2.77	
		Min	2.53	Min	2.42	Min	2.54	
Conductivity	umhos/cm	Avg	343	Avg		Avg	407	
		Max	343	Max	*	Max	407	
		Min	342	Min		Min	407	
Total Trihalomethanes	ug/L	Avg	26.9	Avg		Avg	27.9	
		Max	27.8	Max	*	Max	27.9	
		Min	26.0	Min		Min	27.9	
Turbidity	NTU	Avg	.07	Avg	.05	Avg	.03	
		Max	.11	Max	.11	Max	.08	
		Min	.06	Min	.03	Min	.02	

* Ullrich WTP was offline during monthly sampling event.